



Certificate of Compliance

This certificate is issued for the following:

WATER PRESSURE RELIEF VALVES

Model 43T

| Valve Size, inch NPS | End Configuration | Rated Working Pressure, psi (kPa) |
|----------------------|-------------------|-----------------------------------|
| 3, 4, 6, 8, 10 | 150#/PN16 Flange | 235 (1620) |
| 3, 4, 6, 8 | 300#/PN25 Flange | 365 (2515) |
| 10 | 300#/PN25 Flange | 300 (2070) |

Prepared for:

Bermad Inc
9424 W Little York Rd
Houston, Texas 77040-3316 USA

FM Approvals Class: 1361

Approval Identification: 0003043721

Approval Granted: November 7, 2012

This certificate Supersedes original Certificate of Compliance dated November 7, 2012 due to revisions documented on FM Approved Product Revision Report 797-11812-268 dated March 5, 2013.

Said Approval is subject to satisfactory field performance, continuing follow-up Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne", is written over a horizontal line.

Richard B. Dunne
Group Manager –Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

March 18, 2013

Date

