



Certificate of Compliance

This certificate is issued for the following:

**AUTOMATIC WATER CONTROL VALVES
FOR USE IN DELUGE, PREACTION AND REFRIGERATED AREA SPRINKLER SYSTEMS**

Models 400Y-1M, -2M, -3M, -4M, -7M, -3U, -3U-H, -4U-H, -5M, -6U, -6U-H, -7BM, -7DM and -DP

| Valve Size, inch NPS | End Configuration | Rated Working Pressure, psi (kPa) |
|----------------------|-------------------|-----------------------------------|
| 3, 4, 6, 8 | 150#/PN16 Flange | 235 (1620) |
| 3, 4, 6, 8 | 300#/PN25 Flange | 365 (2515) |

Prepared for:

Bermad Inc
9424 W Little York Rd
Houston, Texas 77040-3316

FM Approvals Class: 1011/1012/1013, 1020, 1021

Approval Identification: 0003043147

Approval Granted: January 11, 2013

This certificate Supersedes the Certificate of Compliance dated March 18, 2013 due to revisions documented on FM Approved Product Revision Report 797-12606-268 dated October 22, 2013.

To verify the availability of the Approved product, please refer to www.approvalguide.com.

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

November 19, 2013

Date

